



Skills requirement

- 1 The internal components of the distribution box, such as leakage circuit breakers 'disconnecting switches' sockets, etc. The distribution box must meet the requirements of the Russian electrical code.
- 2 The rated leakage action current of each outgoing circuit leakage circuit breaker of the distribution box is 30mA, and the rated leakage action time is 0.1S. Among them, the single-phase rated leakage current is 15mA, and the rated leakage operation time is 0.1S.
- 3 In the distribution box, except for the bottom outlet of the 100A outlet circuit box, the other outlet circuits and the outlet circuit of the switch box are symmetrical outlets on both sides of the box.
- 4 The outlet circuit at the bottom of the distribution box should be equipped with an adapter bar to connect with the external cable, and the cable should not be directly connected to the switch connector.
- 5 The distribution box is floor-standing, and the structure should meet the rainproof requirements for outdoor work.
- 6 The isolation switch used for isolation should be equipped with a transparent protective cover. When installing an industrial waterproof socket, it should have a waterproof slope. The socket uses Weipu electrical products.
- 7 There should be a protective panel outside the electrical installation board in the cabinet, with only the operating handle exposed.

			装配图代号			序号		
			图样标记			数量		
			重量			比例		
			共张			第张		
标记处数			更改文件号			签名日期		
设计			标准化			日期		
校对			审定					
审核								
工艺			日期					

配电箱系统图

借通用件登?

描图

描核

旧底?号

底图总号

签字

日期